شركة بشائر البناء للمقاولات
Bashaer Al-Benaa Contracting Company

شركة الشرق للاستشارات الهندسية
ECEC East Consulting Engineering

الهيئة السعودية للسياحة
SAUDI TOURISM AUTHORITY

Site:	FITOUT PROJECT AL-RAED RIYADH	WIR -Area-Bldg site - Disc	REQUEST No.	057	Rev.# Of Copies	1
			Serial	BBC-ECE-AR-WIR-05-R01		
To:	CONSULTANT	Date:	26/12/2022			

WORK INSPECTION REQUEST

We hereby request the Engineer's attendance to inspect the following work:

Level of Inspection: [ ] Hold [ ] Witness [ ] Release Inspection [✓] Handing C

Location of Inspection: 4th Floor

Reference Documents and Attachments: .....

Specification #: [ ] **MIR #:** [ ] **Inspection Checklist #:** [ ] **Certificate:** [ ]

Clearance & Releases: [ ] **Marked-up Approved Shop Drawings:** [ ]

Activity ID/BOQ.: ..... **Date & Time of Inspection:** .....

Previous Inspection History: .....

Meeting Notes #: ..... **Testing Results:** ..... **Issued NCR #:** .....

Description of Work:	**Block work Installations of 1th layer in wet area(Toilets)**
Contractor's QC Report:	**works conforms to specifications**

We certify that the submitted work for inspection has been executed in accordance with the contract's specification and approved shop drawing

PM. Name: Eng.tarek Reafaei	Signature:	Date:	25/12/2022
QC Eng. Name: saleh alzubairi	Signature:	Date:	26/12/2022
DC. Name: Ahmed Gamal	Signature:	Date:	25/12/2022

Engineer's Inspection Comment:

* ATTACHED APPROVED & 4TH FLOOR WET AREA DWG.
* ATTACHED DRAWING HAVE 5TH FLOOR WET AREA.
* CLEAN THE ENTIRE AREA FROM SAND, GARBAGE, ETC
* IF POINT MARKING NOT AS PER DWG CONTRACTOR SUB WILL BE RESPONSIBLE
* SHOULD INSTALL VERTICAL REBAR BEFORE START 1ST LA OF BLOCK WORK

Inspection Status:

A - Approved / Proceed [ ] B - Approved with comments [✓] C - Rejected [ ]

Name: AMIR KHAN **Signature:** **Date:** 27/12/2022

Contractor's Received: .....

Received by: ..... **Signature:** .....

Acceptance of the request does not relieve the contractor from full compliance with the requirements of the contract's documents, dimensions selecting fabrication processes and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe a satisfactory manner and correlating all quantities and conformance with the design concept of the project and general compliance with the informa given in the contract documents

All requests must be submitted at least 24 hours prior to the required inspection and approval.

CC: [ ] AM QA/QC [ ]

Area: .....

Site: .....

Discipline: .....

26.12.22

27/12/2022